

LOCATION 1101 W Franklin CITY Houston

BETWEEN S Dalton STREET & S Firstone STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>105</u>	<u>10-8-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>8</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>9.7</u>			

ENTERS: 1101 BRANCHED INTO:

TAP SIZE: 5/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side of Bldg


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bonett

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1955

DEPTH: 2 Ft. 6 In. LOCATION 17' W of Dalton Ave

"A" P/S READING 1.10 TOTAL ANODES 1# _____ 17# _____ L.R. # 00431431

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY