

LOCATION 1222 W. FRANKLIN BLVD CITY GASTON, VA

BETWEEN VANCE STREET & LINWOOD RD. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>GW</u>	<u>10'</u>	<u>Relocated</u>	<u>3-27-96</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1224 BRANCHED INTO: 1222 - 1220 - 1218

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 14 HRS. BY E. Perry

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH. 2 FT 0 IN LOCATION _____

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: _____

Test Station			ENG. DEPT USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.1</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>		

