

LOCATION 1801 W. Franklin Blv. CITY Castroville
BETWEEN Linwood Rd. STREET & Vance St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>78'</u>	<u>5-8-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>78'</u>			

ENTERS 1301 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 121' S. of center of W. Franklin Blvd

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.
~~MAIN~~ SIZE 3/4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992
DEPTH 2 FT 0 IN LOCATION 775' W. of center of Vance St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	