

LOCATION 1312 W - Franklin Blvd. CITY GASTONIA  
BETWEEN Linwood Rd. STREET & Lance St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>	<u>12-14-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>2</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3'</u>			

ENTERS: 1314 BRANCHED INTO: 1312  
TAP SIZE: 3/4 Straight Plastic Tee PRESSURE 60 P.S.I. INCHES W.C. LOCATION 648' E of C of Linwood Rd.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL  
<sup>Service</sup> MAIN-SIZE 3/4 C.I.      BARE STEEL      COATED STEEL      PLASTIC ☒ YEAR INSTALLED 1994  
DEPTH: 2 Ft. 0 In. LOCATION 79' W of C of Franklin Blvd.

"A" P/S READING Plastic TOTAL ANODES 1\*      17\*      L.R. #     

REMARKS 3/4 Split Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY