

LOCATION 1927 W. Franklin Blvd. CITY CASTON  
BETWEEN DIXIE ST STREET & GARRISON Blvd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>78'</u>	<u>4-13-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>73'</u>			

ENTERS 1927 BRANCHED INTO

TAP SIZE 3/4" PRESSURE LED PSI \_\_\_\_\_ INCHES W.C. \_\_\_\_\_ LOCATION 14' N. of center of Marshall St

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY Sch

PIPE SIZE 3/4" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1975

DEPTH 3 FT 0 IN LOCATION 103' E. of center of Dixie St

\*A\* P/S READING 1.7 TOTAL ANODES I# 0 17# 0 LR # 273935

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	

