

LOCATION 1612 W. FRANKLIN

CITY Canton

BETWEEN Grey

STREET &amp; Yates

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	15	9-29-99		
MAIN TO PROP LINE						
PROP LINE TO BLDG						

ENTERS

BRANCHED INTO

TAP SIZE 3/4 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W C LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GTP


MAIN SIZE \_\_\_\_\_ C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH \_\_\_\_\_ FT \_\_\_\_\_ IN LOCATION

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS

Cut sew. pipe to take fuel tank out of ground  
and tied sew back together, tested pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	OR	P
P/S Pipeline Lead - White Existing Main	I	