

LOCATION 2206 W. Franklin Blvd CITY Gastonia
BETWEEN Myrtle Sch Rd STREET & Packard STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	67'	4-7-97		
MAIN TO PROP. LINE	11	11	6'			
PROP. LINE TO BLDG.	11	11	61'			

ENTERS: 2206 BRANCHED INTO: ✓
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 17' S. of C of
Milton

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY R&L GP
MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1960
DEPTH: 3 FT. 0 IN LOCATION _____

"A" P/S READING .900 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY