

LOCATION 2209 W. FRANKLIN BLU. CITY GAZTONIA
BETWEEN W. FRANKLIN BLU. STREET & W. 2ND AVE STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	D	142'			
MAIN TO PROP. LINE	3/4	D	50'	3-12-96		
PROP LINE TO BLDG.	3/4	D	92'			

ENTERS: 2209 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 114 HRS BY E.P.
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1959
DEPTH. 3 FT 6 IN. LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS

	Test Station		ENG DEPT USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	S	Plastic
	P/S Pipeline Lead - White Existing Main	E	