

LOCATION

2760 W. Franklin Blvd.

CITY

Castonia

BETWEEN

Trakas Blvd.

STREET &

Shannon Bradley Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	123'	10-29-97		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	83'			

ENTERS.

2760

BRANCHED INTO

TAP SIZE:

1/2

PRESSURE

60

PSI

INCHES W C

LOCATION

1161' W of center of

Trakas Blvd.

PRESSURE TEST. @

100

PSI

FOR

1/4

HRS

BY

S. Hunkstetter

MAIN-SIZE

6"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1965

DEPTH:

3 FT

0 IN.

LOCATION

14' N. of center of W Franklin Blvd.

"A" P/S READING

.7

TOTAL ANODES 1#

0


17#

1

L.R. #

738342

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY