


LOCATION 611 FREEDOM MILL RDCITY GASTONIABETWEEN ASPEN DRSTREET & OAKLEY DR

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>plastic</u>	<u>103'</u>	<u>2-26-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>plastic</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>plastic</u>	<u>53'</u>			

ENTERS: 611BRANCHED INTO: 0TAP SIZE: 3/8PRESSURE 60 PSI0 INCHES W.C.LOCATION 304' E of C of ASPEN DRPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY PLMAIN-SIZE 6" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1984DEPTH: 3' FT. 0 IN. LOCATION 13' S of C of FREEDOM MILL RD"A" P/S READING 009TOTAL ANODES 1# 0 17# 0L.R. # 0112158

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY