

LOCATION 616 Freedom Mill Rd. CITY GASTONIA  
BETWEEN OAKley Dr STREET & Aspen STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>89'</u>	<u>7-11-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>81'</u>			

ENTERS: 616 BRANCHED INTO: 0  
TAP SIZE. 3/8" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 43' W of Cof OAKley Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
MAIN-SIZE 6" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1964  
DEPTH: 3 FT 0 IN LOCATION 14' W of Cof Freedom Mill Rd.

"A" P/S READING .60 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # 444423

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY