

LOCATION 719 Freedom mill Rd CITY GASTONIA

BETWEEN Oakley STREET & Birnie LN STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>PLASTIC</u>	<u>173'</u>	<u>11/21/97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>39</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>134'</u>			

ENTERS: 719 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION South side of 719

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY DT

MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1984

DEPTH: 3 FT 0 IN LOCATION West side of Freedom mill Rd

"A" P/S READING 1.90 TOTAL ANODES 1# 0 17# 0 L.R. # 030689

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	S		
P/S Pipeline Lead - White Existing Main	E		

