

LOCATION 1924 Front St. CITY GASTONIA

BETWEEN IVA ST STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>81'</u>	<u>3-8-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>78'</u>			

ENTERS: 1924 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 194' N. of center of

IVA ST


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HARTSHORN

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1990

DEPTH: 3 Ft. 0 In. LOCATION 11' E. of center of Front St.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 92743

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		