

LOCATION 1522 Fuller Dr CITY Castonry
BETWEEN Belmar Dr STREET & Echo Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>24'</u>	<u>10-22-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>16'</u>			


ENTERS: 1522 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 283' SW. of center of Echo Ln

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY S. Hultsluty
MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1964

DEPTH: 3 FT 0 IN LOCATION 112' NW. of center of Fuller Dr

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY