

LOCATION 1533 Fuller Dr. CITY GASTONIA  
BETWEEN 9th Lane STREET & Belmont STREET


|                     | SIZE       | TYPE      | LENGTH    | INSTALLED<br><i>Relocated</i> | RETIRED | RENEWED |
|---------------------|------------|-----------|-----------|-------------------------------|---------|---------|
| MAIN TO BLDG.       | <u>3/4</u> | <u>4w</u> | <u>6'</u> | <u>4-15-93</u>                |         |         |
| MAIN TO PROP. LINE  |            |           |           |                               |         |         |
| PROP. LINE TO BLDG. |            |           |           |                               |         |         |

ENTERS: 1533 BRANCHED INTO: 0  
TAP SIZE: 3/4 50r PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 psi For 14 Hrs. By EP  
MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1972  
DEPTH: 2 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING 1.1 TOTAL ANODES 1\* 1 17\* 5 L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



| Test Station                               |                          |            |
|--|--------------------------|------------|
| Reading & Location                         | Lead                     | Volts      |
| P/S Pipeline Lead - Red<br>New Service     | <u>S</u><br><u>Rifer</u> | <u>1.2</u> |
| P/S Pipeline Lead - White<br>Existing Main | <u>E</u>                 |            |

ENG. DEPT. USE ONLY