

LOCATION 3601 FULMAN CIR. CITY CASTONIA

BETWEEN Kendrick Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>15'</u>	<u>5-20-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>136'</u>			

ENTERS: 3601 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 70' S. of center of

Kendrick Rd.


PRESSURE TEST: @ 105 PSI FOR 14 HRS. BY S. Guffe

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1972

DEPTH: 3 FT. 0 IN. LOCATION 13' W. of center of FULMAN CIR.

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # 26083

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY