

LOCATION 2316 GAINS Ave CITY GAstonia
BETWEEN Shaw STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>Relocated</u>	<u>10-28-97</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 2316 BRANCHED INTO: 2308
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 1 hr HRS BY EP
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1969
DEPTH: 2 FT 6 IN LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:
Retired Riser, Relocated Riser with 10' 3/4 Plastic



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY