

LOCATION 2410 Garden Side CITY Castroville
 BETWEEN Castroville STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>134</u>			<u>✓</u>
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>401</u>		<u>12-14-55</u>	
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>54</u>			

 ENTERS 2410 BRANCHED INTO 0
 TAP SIZE 3/8 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST @ 100 PSI FOR 14 HRS BY ED
 MAIN SIZE 2 1/2 C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED
 DEPTH 3 FT 0 IN LOCATION

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

