

LOCATION 2508 Gardner st CITY Gastonia

BETWEEN Myers st STREET & Kennedy STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>37''</u>		<u>12-2</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>27'</u>			

ENTERS: 2508 BRANCHED INTO: 0

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 387' N of C of Myers

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY BC

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. _____ IN. LOCATION 15' E of C of Gardner st

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - L.R. # _____

REMARKS: _____

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>		