

LOCATION 3015 Gardner Park Dr. CITY Carson
BETWEEN Downey Pl STREET & Derby Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>1'</u>	<u>4-22-94</u>	<u>Tied over 185' of</u>	
MAIN TO PROP. LINE					<u>EXT 3/4" CW to EXT 4"</u>	
PROP. LINE TO BLDG.					<u>plastic main</u>	

ENTERS: 3015 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By EP


MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING TOTAL ANODES 1* 1 17* L.R. #

REMARKS:

Bonded Insulated Vessor
Tracer wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1/2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY