

LOCATION 3039 + 3101 Gardner ParkCITY GastoniaBETWEEN Bridle PathSTREET & Eastwood

STREET:

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED ^{TIED OVER}	RENEWED
MAIN TO BLDG.	3/4"	ctw	-0-	TIED OVER 4-23-88 (3101) 145' 3/4"		
MAIN TO PROP. LINE				ctw 2-20-80	33' 3/4" ctw	
PROP. LINE TO BLDG.						

ENTERS: 3039BRANCHED INTO: -TAP SIZE: 1/2

PRESSURE


60

P.S.I.

INCHES W.C.

LOCATION 18' south ofGardner ParkPRESSURE TEST: @ 100 psi For 14 Hrs. By M ParkerMAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 93DEPTH: 3 Ft. 0 In.LOCATION 78' East of Bridle Path"A" P/S READING .95TOTAL ANODES 1* 1 17* L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	ctw Riser .95-
P/S Pipeline Lead - White Existing Main	E	