

LOCATION 3141 Gardner Park Drive

CITY Gastonia

BETWEEN Cheswick

STREET & Eastwood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	CPW	-0-	TIED OVER 4-23-94		
MAIN TO PROP. LINE				176' 3/4" CPW		
PROP. LINE TO BLDG.				9-22-64		

ENTERS: 3141

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 18' south of
Gardner Park Drive


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 93

DEPTH: 3 Ft. 0 In. LOCATION 114' west of Cheswick

"A" P/S READING 1.1 TOTAL ANODES 1# 1 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.1 CPW Riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY