

LOCATION 3341 Gardner Park Dr. CITY GASTONIA

BETWEEN melody STREET & Deerwood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>114'</u>	<u>1/23/97</u>		
MAIN TO PROP. LINE	<u>3/4</u>		<u>20'</u>			
PROP LINE TO BLDG.	<u>3/4</u>		<u>94'</u>			

ENTERS 3341 BRANCHED INTO:

TAP SIZE 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION West side of 3341


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1968

DEPTH: 3 FT. 0 IN LOCATION South side of Center Line Gardner Park Dr.

"A" P/S READING 1.30 TOTAL ANODES 1# _____ 17# _____ L.R. # 026606

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY