

LOCATION 1710 Garland Ave CITY Castroville
BETWEEN Shannon Ln STREET & Belmar STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>4'</u>	<u>8-13-54</u>	<u>Tied over</u>	<u>89' of Ext</u>
MAIN TO PROP. LINE					<u>3/4 CW to ext</u>	<u>2" Plastic</u>
PROP. LINE TO BLDG.					<u>Main</u>	

ENTERS: 1710 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1953
DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:

Ticker wire tied off at main

Bonded Insulated dresser



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY