

LOCATION 1815 + 1815 1/2 Garland Ave. SPLIT Services CITY EASTON IA
BETWEEN SHARON Lane STREET & Belmar Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>	<u>8-13-94</u>	<u>Tied over 96'</u>	<u>Existing 3/4 Plastic</u>
MAIN TO PROP. LINE					<u>ON 1815</u>	<u>Tied over 70'</u>
PROP. LINE TO BLDG.					<u>Existing 3/4 Plastic</u>	<u>ON 1815 1/2</u>


ENTERS: 1815 BRANCHED INTO: 1815 1/2
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 83' Euf. of Sharon Lane

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993
DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of Garland Ave.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. # 350971

REMARKS: Split Services

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY