

LOCATION 208 E. GARRISON BLVD.CITY GASTONIABETWEEN UNION RD.STREET & OAKLAND ST

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>plastic</u>	<u>72'</u>	<u>12-2-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>plastic</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>plastic</u>	<u>32'</u>			

ENTERS:

BRANCHED INTO 208

TAP SIZE 1/2 PRESSURE 60 PSI 0 INCHES W C LOCATION 84' N of C of  
E. GARRISON BLVD


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY P.R

Service MAIN SIZE 3/4 C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 1 FT IN LOCATION 275' E of C of OAKLAND ST

"A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 L.R. # 00684592

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY