

LOCATION 216 E. GARRISON BlvdCITY GASTONIABETWEEN OAKLANDSTREET & UNION

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>132'</u>	<u>11-1-95</u>	<u>11-1-95</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>75'</u>		<u>105' 3/4"</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>57'</u>		<u>CRW</u>	

ENTERS: 216

BRANCHED INTO:


1968TAP SIZE: 3/8PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 39' south ofGARRISON BlvdPRESSURE TEST: @ 100 psiFor 1/4 Hrs.By M ParkerMAIN-SIZE 10"C.I. BARE STEEL COATED STEEL XPLASTIC YEAR INSTALLED 1969DEPTH: 3 Ft. 0 In.LOCATION 216' E. OF OAKLAND"A" P/S READING 1.7TOTAL ANODES 1* 0 17* 0L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.7 RISE</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY