

LOCATION (607) + 611 E. Garrison Blvd.

CITY GASTONIA

BETWEEN ADP.E. AVON

STREET & Fern Forest

STREET

	SIZE	TYPE	607 LENGTH 64		INSTALLED	RETIRED		RENEWED
MAIN TO BLDG.	3/4	Ø	110'	10'	4-8-95	4-8-95		4-8-95
MAIN TO PROP. LINE	3/4	P	10'			607	6"	
PROP. LINE TO BLDG.	3/4	P	100			130'	25'	

ENTERS: 607

BRANCHED INTO: 64

TAP SIZE: 3/8

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION 33' S of Garrison


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1969

DEPTH: 3 Ft. 0 In. LOCATION 135' E OF AVON

"A" P/S READING 2.0 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-riser
P/S Pipeline Lead - White Existing Main	E	