

LOCATION 929 E. garrison Blv. ste 2 CITY gastonia
BETWEEN S. church STREET & Reid STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PIA.</u>	<u>10'</u>		<u>11-10-97</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>PIA.</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PIA.</u>	<u>12'</u>			


ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 218ft E of S church

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY James Dayton
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997
DEPTH: 3 FT 0 IN. LOCATION 109ft Not E. 8th Ave.

"A" P/S READING PIA. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:
Fusion By chris Scott

Total pipe 10ft.
Total Bore 0ft.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY