

LOCATION 1005 E. Garrison Blv CITY Castania
 BETWEEN Reid St. STREET & Laural Lane. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	52'		11-26-01	11-26-01
MAIN TO PROP LINE	5/8"	P	8'		"	
PROP LINE TO BLDG	5/8"	P	44'		"	

ENTERS 1005 BRANCHED INTO Ø
 TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 92' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody at center of Reid St.

MAIN-SIZE 10" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH 6' FT 0" IN LOCATION 36' south of center of Garrison Blv.

"A" P/S READING 1.5 TOTAL ANODES I# Ø 17# Ø LR # Ø

REMARKS New 5/8" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	rigor