

LOCATION 1225 Garrison Blvd CITY Castonia

BETWEEN Laurel Lane STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4'</u>	<u>P</u>	<u>165'</u>			<u>7-26-97</u>
MAIN TO PROP. LINE	<u>3 1/4'</u>	<u>P</u>	<u>10'</u>			<u>Tied over 133'</u>
PROP. LINE TO BLDG.	<u>3 1/4'</u>	<u>P</u>	<u>155'</u>			<u>Existing 3 1/4" Plastic Service</u>

ENTERS: 1225 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 40 PSI INCHES W.C. LOCATION 194' E. of center of

Laurel Lane


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY S. Huff & Peltz

MAIN-SIZE 10' C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH: 4 FT. 0 IN. LOCATION 40' S. of center of Garrison Blvd.

"A" P/S READING P.4 TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY