

LOCATION 110 W. Garrison Blvd. CITY GASTONIA  
BETWEEN S. South St. STREET & S. Marietta St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85'</u>	<u>2-9-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>80'</u>			


ENTERS: 110 BRANCHED INTO: 0  
TAP SIZE: 3/4" stub PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 264' W of C of S. Marietta St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL  
MAIN-SIZE 10" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: 2 FT 0 IN. LOCATION 38' N of C of W. Garrison Blvd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 065797

REMARKS: \* Came off Existing 3/4 Plastic Stub.

	Test Station			ENG. DEPT. USE ONLY	
	Reading & Location	Lead	Volts		
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>		
	P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>		