

LOCATION 609 W Garrison Blvd CITY GAstonia

BETWEEN Clay STREET & JACKSON STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>39'</u>	<u>11/13/97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>33'</u>			

ENTERS: 609 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION West side of 609


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT

MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1969

DEPTH 3 FT 0 IN LOCATION South side of W Garrison Blvd

"A" P/S READING 1.20 TOTAL ANODES 1# 0 17# 0 L.R. # 018873

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY