

LOCATION 900 W Garrison Blvd CITY GASTONIA  
BETWEEN Paramount STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>136'</u>			<u>12/17/94</u>
MAIN TO PROP. LINE	<u>3/4"</u>		<u>75'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>61'</u>			

ENTERS: 900 BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION East side of 900

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT  
MAIN-SIZE 10" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1969  
DEPTH: 3 Ft. 0 In. LOCATION South side of W Garrison Blvd

"A" P/S READING 1.20 TOTAL ANODES 1\* 0 17\* 0 L.R. # 510550

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY