

LOCATION 1310 W BARRISON Blvd CITY GASTAVIA
BETWEEN EMERSON ST STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	18'			12/3/94
MAIN TO PROP. LINE	3/4"		18'			
PROP. LINE TO BLDG.	3/4"		18'			

ENTERS: 1310 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION W side OF 1310

PRESSURE TEST: @ 100 psi For 44 Hrs. By DF
5/8" MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994
DEPTH: 1 Ft. 6 In. LOCATION EAST side of 1312

"A" P/S READING 103 TOTAL ANODES 1* 0 17* 0 L.R. # 510503

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY