

LOCATION 1312 W BARRISON Blvd CITY CANTONIA
BETWEEN Emerson ST STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>2 1/2"</u>	<u>BARE</u>	<u>100</u>		<u>12/3/94</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: BRANCHED INTO:
TAP SIZE: PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION

PRESSURE TEST: @ _____ psi For _____ Hrs. By _____
MAIN-SIZE _____ C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____
DEPTH: Ft. In. LOCATION

"A" P/S READING 0 TOTAL ANODES 1 * 17 * 0 L.R. # 510503

REMARKS: EX BARE MAIN TO BE RETIRED


Retired Service Purged

With Air And

Capped With Main

Bare Main Replacement

Evergreen



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY