


LOCATION 1757, 1763, & 1771 W. Garrison Blvd.CITY BostonBETWEEN Yates St.STREET & 3rd St.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED Tied Over ^{REMOVED}
MAIN TO BLDG.	<u>3/4</u>	<u>CHW</u>	<u>21'</u>	<u>12-3-94</u>	<u>64' Existing 3/4 CHW ON 1963</u>
MAIN TO PROP. LINE					<u>123' Existing 3/4 CHW ON 1771</u>
PROP. LINE TO BLDG.					<u>40' Existing 3/4 CHW ON 1757</u>

ENTERS: 1763BRANCHED INTO: 1757 & 1771TAP SIZE: 3/8PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 186' E of 3rd St.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1969DEPTH: 3 Ft. 0 In. LOCATION 40' S of 3rd Garrison Blvd."A" P/S READING 1.2 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

Bare Main Replacement
Program

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red	S	Riser 1763	1.2
New Service		Riser 1771	1.2
		Riser 1763	1.2
P/S Pipeline Lead - White	E		
Existing Main			