

LOCATION 1764 W. GARRISON Blvd.CITY CASTONIABETWEEN 3rd St.STREET & Yates St.


STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>188'</u>	<u>12-3-94</u>	<u>60' 3/4" CW</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>80'</u>		<u>Pipe to be</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>108'</u>		<u>Retired with MAIN</u>	

ENTERS: 1764BRANCHED INTO: 0TAP SIZE: 3/8PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 188' E of Cor 3rd St.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 10" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1969DEPTH: 3 Ft. 0 In. LOCATION 40' S of Cor Garrison Blvd."A" P/S READING 1.2 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

~~Bare Main Replacement~~  
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser. Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY