

LOCATION 1857 Gaston Day School Rd CITY Gastonia
BETWEEN Hemphreys Dr STREET & Lincoln Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>128'</u>	<u>9-11-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>13'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>115'</u>			


ENTERS: 1857 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 68 PSI _____ INCHES W.C. LOCATION 598' W. of center of Lincoln Ln.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. H. H. H. H. H.
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1979

DEPTH: 5 FT 0 IN. LOCATION 14' N. of center of Gaston Day School Rd

"A" P/S READING 1.2 TOTAL ANODES 1# 3 17# 0 L.R. # 532387

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY