

LOCATION 2001 Gaston Day sch. Rd. CITY Gaston, IA
BETWEEN Kendrick Rd. STREET & Union Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>294'</u>	<u>4-5-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>294'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>294'</u>	<u>"</u>		

ENTERS 2001 Gaston Day sch. Rd. BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 220' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Moody
Center of J.B. Davis Dr.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 5' FT 0" IN LOCATION 893' south of center of Gaston Day sch. Rd.

"A" P/S READING 11A TOTAL ANODES 1# Ø 17# Ø LR # 00253956

REMARKS New 3/4" P. Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>