

LOCATION 2635 Gaston Day School Rd CITY GASTONIA

BETWEEN LisMORE LN STREET & Candleberry STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	Plastic	138'	12/7/98		
MAIN TO PROP. LINE	3/4'		45'			
PROP. LINE TO BLDG.	3/4"		93			

ENTERS: 2635 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 100 PSI INCHES W.C. LOCATION South side of 2635

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 4" C.I.        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1990

DEPTH: 3 FT. 0 IN LOCATION East side of Gaston Day School Rd

"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 259286

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY