

LOCATION 2911 GASTON DAY School Rd CITY Gastonia

BETWEEN Stoneleigh STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>141'</u>	<u>12/9/95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>41'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>100'</u>			

ENTERS: 2911 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION West side of 2911


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By _____

MAIN-SIZE 4' C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1970

DEPTH: 2 Ft. 6 In. LOCATION EAST side of GASTON DAY School Rd

"A" P/S READING 1.30 TOTAL ANODES 1# _____ 17# _____ L.R. # 618445

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S, Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY