

LOCATION 907 S Gibbons St. CITY Cast.

BETWEEN Eight Ave. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>20'</u>			<u>3-26-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>12'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>8'</u>			

ENTERS: SAME BRANCHED INTO: 909 S Gibbons St.

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 133' from @ of

Eight St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY MLL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION East side of Gibbons St.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY