

LOCATION 911 S Gibbons st. CITY CRST.

BETWEEN Eight Ave. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>47'</u>			<u>3-2797</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>44'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 188' From @ OF

Eight Ave.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY DAI

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 1 IN. LOCATION EASTside of Gibbons st.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY