

LOCATION 916 S GIBBONS ST. CITY CAS.

BETWEEN Dead End STREET & Eight Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>72'</u>			<u>3-27-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>29'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>43'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 29' from Dead End


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DNF

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION Eastside of Gibbons St.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY