

LOCATION 40 Gilmer St CITY GASTONIA
BETWEEN Wood STREET & York STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>17'</u>	<u>3-27-98</u>	<u>3-27-98</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>		<u>35- 1" BME</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>12'</u>		<u>orig Inst</u>	


ENTERS: 40 BRANCHED INTO: ()
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 15 S of Gilmer

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY M Parker
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 98

DEPTH: 3 FT 0 IN LOCATION 138' E of Wood St

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.102</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY