

LOCATION 86 & 85 Gilmer St CITY Gresham
BETWEEN Clyde ~~ST~~ STREET & Wood St STREET


	SIZE	TYPE	<u>86</u> LENGTH <u>85</u>	INSTALLED	RETIRED	<input checked="" type="checkbox"/> RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>75'</u> <u>4'</u>		<u>3-</u>	<u>28-98</u>
MAIN TO PROP. LINE	<u>7</u>	<u>1</u>	<u>3'</u> <u>3'</u>			
PROP. LINE TO BLDG.	<u>7</u>	<u>1</u>	<u>72</u> <u>38'</u>			

ENTERS: 86 BRANCHED INTO: 85
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST. @ 140 PSI FOR 1 1/2 HRS BY SE
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED _____
DEPTH: 3 FT 0 IN LOCATION _____

"A" P/S READING PL TOTAL ANODES 1# 17# _____ L.R. # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Rise</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY