

LOCATION

93 &amp; 92 Gilmer St

CITY

Gastonia

BETWEEN

Wood

STREET &amp;

Clyde

STREET

	SIZE	TYPE	93 LENGTH 92	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	77' 46'		3-	30-58
MAIN TO PROP. LINE	"		38' 18'			
PROP LINE TO BLDG.	"		47' 28'			

ENTERS

93

BRANCHED INTO: 92

TAP SIZE:

3/4

PRESSURE

60

PSI

INCHES W/C

LOCATION

PRESSURE TEST. @

120

PSI

FOR 1/4 HRS

BY

SE

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1998

DEPTH:

3 FT 0

IN

LOCATION

"A" P/S READING


P2

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

Riser

Plastic

P/S Pipeline Lead - White  
Existing Main

E

ENG. DEPT. USE ONLY