

LOCATION 99 Gilmer St CITY GASTONIA
BETWEEN WOOD STREET & CLYDE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>55'</u>	<u>9-11-95</u>	<u>9-11-95</u>	
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10</u>		<u>59' 1" Bare</u>	
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>45</u>		<u>(19)</u>	

ENTERS: 99 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 20th P.S.I. _____ INCHES W.C. LOCATION 7' N OF Gilmer


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M Parker

MAIN-SIZE 2" C.I. _____ BARE STEEL X COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1953

DEPTH: 3 Ft. 0 In. LOCATION 385' W of Wood St

"A" P/S READING 3 TOTAL ANODES 1# _____ 17# 1 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY