

LOCATION 4423 Ginger Dr. CITY GASTONIA
BETWEEN Union Rd. STREET & Irish Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>120'</u>	<u>1-17-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>80'</u>			

ENTERS: 4423 BRANCHED INTO: 0
TAP SIZE. 3/8 PRESSURE 40 PSI _____ INCHES W.C. LOCATION 257' N of C of Irish Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1971
DEPTH: 3 FT 0 IN LOCATION 18' E of C of Ginger Dr.

"A" P/S READING 1.5 TOTAL ANODES 1# 0 17# 0 L.R. # 023097

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY